

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YU847		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner CARLSON, GREG						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 675 110TH AVE						Town of LINCOLN						675					
City AMERY						State WI		Zip Code 54001				Street Address or Road Name and Number 110TH AVE					
County Polk		Co. Permit #		Notification # 7090588601		Completed 02-28-2018		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) BRYAN COX				Lic. # 6644		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.37175 °N -92.2998 °W				Method Code SCR002			
Address BLC WELL DRLG & PUMP SERV MILLTOWN WI 54858				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 1 33 N 16 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 2													
3. Well serves 1 # of HOUSE Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		138		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				T - Z - TAN/BROWN, CLAY & GRAVEL B - Y - BLACK, SAND & GRAVEL R - C - RED, CLAY T - Y - TAN/BROWN, SAND & GRAVEL		Surface 53 64 130 130		53 64 130 138			
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 50 ft. below ground surface				11. Well Is 18 in. above grade			
6		CASING STEEL WELDED EXELL 19LB A53 6.625X.280				Surface		135		10. Pump Test Pumping level 60 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
6		JOHNSON SS 20 SLOT				135		138									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes							
GRANULAR BENTONITE				Surface				2									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
BC														04-03-2018			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		50

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	04/03/2018	WATER TEST WILL BE LATE

Created On: 04-05-2018

Updated On: 06-28-2018

Review Status: APPROVED