Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YU850

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNSON, SHAWN	Phone #: (608)243-2848
Mailing Address: 2066 240TH AVE	
City: LUCK	State: WI — Zip Code: 54853
County: Polk	Co. Permit #:
Notification #: 7101334901	Completed: 03-12-2018
Well Constructor (Business Name): BRYAN COX	Lic. #: 6644
Facility ID # (Public Wells):	
Address: BLC WELL DRLG & PUMP SERV MILLTOWN WI 54858	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4	

1. Well Location

Town of EUREKA

Fire # (if avail.):

Street Address or Road Name and Number: 240TH AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.55362 °N -92.58375 °W

Method Code: SCR002

NE	NW	Section	Township	Range
or Govt Lot #		3	35 N	18 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of home

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	136

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R - Z -	Red, Clay & Gravel	Surface	92
T - S -	Tan/Brown, Sand	92	105
R - Z -	Red, Clay & Gravel	105	130
T - G -	Tan/Brown, Gravel/Cobbles/Boulders/Stones	130	136

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	casing steel welded ispco a53 19lb 6.625x.280	Surface	136
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method mounded

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Granular bentonite	Surface		2

9. Static Water Level

75 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
bc		04-24-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		25

Comment:

Created On: 04-30-2018 Updated On: 06-30-2020 Review Status: APPROVED