Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YV007

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RAMOS, MICHELLE	Phone #: 715344835
Mailing Address: 912 SANDY LANE	
City: STEVENS POINT	State: WI — Zip Code: 54482
County: Portage	Co. Permit #:
Notification #: 7385001701	Completed: 08-30-2018
Well Constructor (Business Name): SOIK R J PLBG & HTG INC	Lic. #: 2868
Facility ID # (Public Wells):	
Address: PO BOX 265 1512 WATER ST STEVENS POINT WI 54481-0265	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 6	

1. Well Location

Town of HULL	Fire # (if avail.): 912
Street Address or Road Name and Number: SANDY LANE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.5267 °N -89.5197 °W	Method Code: GCD013
NE NW or Govt Lot #:	Section: 35 — Township: 24 N — Range: 8 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: WELL FAILED

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? Yes

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	50

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STAINLESS STEEL A53B 18.97 EXCEL WELD,=	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	12 SLOT STAINLESS STEEL TELESCOPING	46	50

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	46	1 S

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 29 ft. below surface

Pumping at 18 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

OLD WELL ABANDONED

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WES	480	09-04-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LM	7416	09-04-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 09-12-2018 Updated On: 10-15-2026 Review Status: APPROVED