Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YV008

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: REABE SPRAYING SERVICE			Phone #: (715)341-9393
Mailing Address: PO BOX 935			
City: PLOVER	State: WI	Zip Code: 54467	
County: Portage	Co. Permit #:	Notification #: 7423492001	Completed: 10-17-2018

Well Constructor (Business Name): SOIK R J PLBG & HTG INC	Lic. #: 2868	Facility ID # (Public Wells):	
Address: PO BOX 265 1512 WATER ST STEVENS POINT WI 54481-0265		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 5	

3. Well serves 1 # of OFFICE AND SHOP
Non-community
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of PLOVER

Fire # (if avail.): 5498

Street Address or Road Name and Number: TAFT AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.4203 °N	-89.5497 °W			GPS008
SE NE or Govt Lot #	Section: 4	Township: 22 N	Range: 8 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	30

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	Y	C	T-TAN/BROWN V-NON-CAVING Y-SAND & GRAVEL C-CLAYEY	Surface	15
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	15	30

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL A53B 18.97 IPSCO WELD	Surface	26
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	12 SLOT STAINLESS STEEL TELESCOPING	26	30

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	26	1 S

9. Static Water Level
9 ft. below ground surface

10. Pump Test
Pumping level 12 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WS	480	10-17-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LM	7416	10-17-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 07-01-2019 Updated On: 07-03-2019 Review Status: APPROVED