

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YV009		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ALLEMAN, KARL & KATHLEEN						Phone #									
Mailing Address N2658 PLEASANT PARK LN						Town of FARMINGTON						Fire # (if avail.) N2658			
City FARMINGTON				State WI		Zip Code 54981									
County Waupaca		Co. Permit #		Notification # 7461521501		Completed 11-20-2018		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) SOIK R J PLBG & HTG INC				Lic. # 2868		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3362 °N -89.1695 °W				Method Code GPS008	
Address PO BOX 265 1512 WATER ST STEVENS POINT WI 54481-0265				Well Plan Approval #				NW SE		Section 33		Township 22 N		Range 11 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well				of previous unique well # constructed in	
3. Well serves 1 # of HOME				Hicap Well ? No				Reason for replaced or reconstructed well ?							
Private,potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ? No				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		43		No Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)				To (ft.)			
T Q Y				T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL				Surface				43			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is	
6		STEEL A5313 19.97 WHEATLAND WELD				Surface		39		19.6 ft. below ground surface				22 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes	
6		15 SLOT STAINLESS STEEL TELESOPING				39		43		Pumping level 19.8 ft. below surface				Disinfected ? Yes	
										Pumping at 17 GP M for 12 Hrs.				Capped ? Yes	
										Pumping Method ? Test Pump					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No					
GRANULAR BENTONITE				Surface		39		1 S		Filled & Sealed Well(s) as needed? No					
13. Constructor / Supervisory Driller															
WS				Lic #		480		Date Signed		11-20-2018					
Drill Rig Operator				Lic or Reg #		LM		Date Signed		11-20-2018					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 12-21-2018

Updated On: 05-08-2020

Review Status: APPROVED