Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YV009

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	ALLEMAN, KARL & KATHLEEN
Phone #	
Mailing Address	N2658 PLEASANT PARK LN
City	FARMINGTON
State	WI
Zip Code	54981
County	Waupaca
Co. Permit #	
Notification #	7461521501
Completed	11-20-2018
Well Constructor (Business Name)	SOIK R J PLBG & HTG INC
Lic. #	2868
Facility ID # (Public Wells)	
Address	PO BOX 265 1512 WATER ST STEVENS POINT WI 54481-0265
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	85

1. Well Location

Fire # (if avail.)	N2658
Town of	FARMINGTON
Street Address or Road Name and Number	PLEASANT PARK LN
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	44.3362 °N -89.1695 °W
Method Code	GPS008
NW SE or Govt Lot #	
Section	33
Township	22 N
Range	11 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	43

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL A5313 19.97 WHEATLAND WELD	Surface	39
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	15 SLOT STAINLESS STEEL TELESCOPING	39	43

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	39	1 S

9. Static Water Level

19.6 ft. below ground surface

10. Pump Test

Pumping level 19.8 ft. below surface

Pumping at 17 GP M for 12 Hrs.

Pumping Method ? Test Pump

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WS	480	11-20-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LM	7416	11-20-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 12-21-2018 Updated On: 10-15-2026 Review Status: APPROVED