

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YV159		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner 3M - GREYSTONE PLANT						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 1207						Town of MAINE						4099					
City WAUSAU						State WI		Zip Code 54402				Street Address or Road Name and Number N 4TH AVENUE					
County Marathon		Co. Permit #		Notification #		Completed 11-02-2018		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) MUNICIPAL WELL & PUMP/MIDWEST WELL				Lic. # 13		Facility ID # (Public Wells) 737069190		Latitude / Longitude in Decimal Degree (DD) 45.0145 °N -89.6376 °W				Method Code GPS008					
Address 1212 STORBECK DR WAUPUN WI 53963				Well Plan Approval # N/A		NW NE Section Township Range or Govt Lot # 11 29 N 7 E		2. Well Type Replacement of previous unique well # AN644 constructed in 1954 Reason for replaced or reconstructed well ? CASING FAILURE Construction Type Drilled									
				Approval Date (mm-dd-yyyy) 07-20-2018													
Hicap Permanent Well # 92679		Common Well #		Specific Capacity													
3. Well serves # of INDUSTRY Non-community				Hicap Well ? Yes Hicap Property ? Yes Hicap Potable ? No													
Heat Exchange # of drillholes																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
24		Surface		97						S G		S-SAND G-W/GRAVEL/STONES		Surface		97	
						<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ____in. dia... <u>No</u> <u>Yes</u> Dual Rotary <u>No</u> <u>Yes</u> Temp. Outer Casing 24in. dia <u>Yes</u> Removed? 97depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		45 ft. below ground surface		36 in. above grade					
18		NEW PRIME 304 SS WELL CASING ASTM A53 .375" WALL				Surface		77		10. Pump Test Pumping level 69 ft. below surface Pumping at 410 GP M for 24 Hrs. Pumping Method ? Test Pump		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
18		304 SS , PS, .035" SLOT HIQ				77		97									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?		No			
Method												Filled & Sealed Well(s) as needed?		Yes			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
NEAT CEMENT GROUT				Surface		60		100 S									
RED FLINT #40 SLOT				60		97											
13. Constructor / Supervisory Driller												Lic #		Date Signed			
TG												4135		11-13-2018			
Drill Rig Operator												Lic or Reg #		Date Signed			
MR												7819		11-13-2018			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Quarry	=	1100

Comment: 8/21/19: DISCUSSED WITH WU STAFF & THIS WELL LOCATION IS OKAY AS IT IS WITHIN 75' OF THE PREVIOUS WELL. DLR

Created On: 01-07-2019

Created by: MWPUMP

Updated On: 08-21-2019

Updated by: PWS TRANSFER