

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YV710		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KRIVINCHUK, DAVE						Phone # (218)348-0494		1. Well Location				Fire # (if avail.)					
Mailing Address 4157 E LEGGATE RD						City of SUPERIOR						Street Address or Road Name and Number 4157 E LEGGATE RD					
City SUPERIOR				State WI		Zip Code 54880				Subdivision Name				Lot #		Block #	
County Douglas		Co. Permit #		Notification # 7018071301		Completed 11-17-2017		Latitude / Longitude in Decimal Degree (DD) 46.5273 °N -92.09003 °W				Method Code VRT001					
Well Constructor (Business Name) ROBERT W KENT				Lic. # 6791		Facility ID # (Public Wells)				SE NW Section Township Range or Govt Lot # 26 47 N 14 W		Well Plan Approval #					
Address KENT WELL DRILLING WRENSHALL MN 55797				Approval Date (mm-dd-yyyy)		2. Well Type New Well						of previous unique well # constructed in					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				Reason for replaced or reconstructed well ?							
3. Well serves 1 # of home						Hicap Well ? No				Construction Type Drilled							
Private, potable						Hicap Property ? No				Heat Exchange ___ # of drillholes							
Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
6		Surface		204		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>Yes</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)									
T - S -		Tan/Brown, Sand				Surface		20									
G - P G		Gray, Hardpan, w/Gravel/Cobbles/Boulders/Stones				20		88									
R - B -		Red, Basalt or Trap Rock				88		204									
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		Weatland Sch 40 480 19.75				Surface		88									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material																	
Method granular																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
Granular bentonite				Surface		88											
9. Static Water Level																	
28 ft. below ground surface																	
10. Pump Test																	
Pumping level 120 ft. below surface																	
Pumping at 25 GP M for 2 Hrs.																	
Pumping Method ?																	
11. Well Is																	
18 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed? No																	
none																	
13. Constructor / Supervisory Driller				Lic #		Date Signed											
bk						12-30-2017											
Drill Rig Operator				Lic or Reg #		Date Signed											
BK						12-30-2017											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		45	Septic or Holding, or POWTS Tank		75

Comment: 1/25/18: DRLR CORRECTED LAT/LONG. DLR

Created On: 01-02-2018

Updated On: 06-25-2020

Review Status: APPROVED