Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YV832

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	HUGHEY, LANCE
Phone #	
Mailing Address	PO BOX 361
City	LACROSSE
State	WI
Zip Code	54602

County	Co. Permit #	Notification #	Completed
La Crosse	33857	7181534701	05-09-2018

1. Well Location

Fire # (if avail.)	Town of	Street Address or Road Name and Number	Subdivision Name	Lot #	Block #
W2137	FARMINGTON	DAVIS CREEK RD			

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
JAKE J SCHAITEL	3822	

Address: TRI COUNTY WELL DRILLING, SPARTA WI 54656-5603

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.0517 °N	-91.0155 °W			GCD013

SE	NE	Section	Township	Range
or Govt Lot #		7	18 N	5 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

3. Well serves 1 # of home

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	-	Tan/Brown, Caving, Sand	Surface	56
G	Q	U	-	Gray, Caving, Mud or Muck	56	67
U	H	H	-	Blue, Hard/Firm, Shale	67	73
G	H	N	-	Gray, Hard/Firm, Sandstone	73	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	new pe black steel astma 53 18.95 280 wall weld usa ipsco	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

45 ft. below ground surface

10. Pump Test

Pumping level 87 ft. below surface

Pumping at 18 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

19 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method drive thru

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Granular bentonite	Surface	10	4

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
js		05-11-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		79

Type	Qualifier	Distance
Building Overhang		31
Septic or Holding, or POWTS Tank		55

Comment:

Created On: 05-14-2018 Updated On: 04-30-2020 Review Status: APPROVED