Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YV833

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HUGHEY, LANCE	Phone #
Mailing Address: PO BOX 361	
City: LACROSSE	State: WI — Zip Code: 54602

County	Co. Permit #	Notification #	Completed
La Crosse	33857	7180128001	05-10-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
JAKE J SCHAITEL	3822	

Address: TRI COUNTY WELL DRILLING, SPARTA WI 54656-5603

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

3. Well serves 1 # of pond
Private, non-potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.)
W2137

Town of FRAMNGTON

Street Address or Road Name and Number: DAVIS CREEK RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.0517 °N -91.0155 °W	GCD013

SE NE or Govt Lot #	Section	Township	Range
	7	18 N	5 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	140

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q S -	Tan/Brown, Caving, Sand	Surface	95
G H N -	Gray, Hard/Firm, Sandstone	95	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	new pe black steel astma wall weld usa ipsco	Surface	96
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: drive thru

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Granular bentonite	Surface	4	3

9. Static Water Level
38 ft. below ground surface

10. Pump Test
Pumping level 127 ft. below surface
Pumping at 35 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
19 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
js		05-11-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 05-14-2018 Updated On: 04-30-2020 Review Status: APPROVED