

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YV833		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HUGHEY, LANCE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 361						Town of FRAMNGTON						W2137					
City LACROSSE						State WI		Zip Code 54602				Street Address or Road Name and Number DAVIS CREEK RD					
County La Crosse		Co. Permit # 33857		Notification # 7180128001		Completed 05-10-2018		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) JAKE J SCHAITEL				Lic. # 3822		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0517 °N -91.0155 °W							
Address TRI COUNTY WELL DRILLING SPARTA WI 54656-5603				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 7 18 N 5 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4													
3. Well serves 1 # of pond Private, non-potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		140		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>Yes</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				T Q S - Tan/Brown, Caving, Sand G H N - Gray, Hard/Firm, Sandstone		Surface 95		95 140			
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 38 ft. below ground surface				11. Well Is 19 in. above grade			
6		new pe black steel astma wall weld usa ipsco				Surface		96		10. Pump Test Pumping level 127 ft. below surface Pumping at 35 GP M for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material Method drive thru Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement Granular bentonite Surface 4 3												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller												Lic #		Date Signed			
js														05-11-2018			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 05-14-2018

Updated On: 04-30-2020

Review Status: APPROVED