Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YV836

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KNOLL, BRAD	Phone #
Mailing Address: 415 L ST	
City: SPARTA	State: WI — Zip Code: 54656
County: Monroe	Co. Permit #: — Notification #: 7183919501 — Completed: 05-12-2018
Well Constructor (Business Name): JAKE J SCHAITEL	Lic. #: 3822 — Facility ID # (Public Wells):
Address: TRI COUNTY WELL DRILLING, SPARTA WI 54656-5603	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of LEON	Fire # (if avail.): 7644
Street Address or Road Name and Number: JACKPINE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.8989 °N -90.8394 °W	Method Code: GCD013
NE NW or Govt Lot #:	Section: 3 — Township: 16 N — Range: 4 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of home

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	65

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	Yes
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q S -	Tan/Brown, Caving, Sand	Surface	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	new bell end sdr21 crestline pvc	Surface	61
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	stainless steel johnson 15 slot screen	61	65

7. Grout or Other Sealing Material

Method: Tremie Pipe - Pumped

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
High solid bentonite grout	Surface	51	11

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 57 ft. below surface

Pumping at 12 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
js		05-14-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		97

Type	Qualifier	Distance
Building Overhang		41
Septic or Holding, or POWTS Tank		88

Comment:

Created On: 05-14-2018 Updated On: 04-29-2020 Review Status: APPROVED