Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW011

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OHEARN, CHRIS	Phone #
Mailing Address: W7889 PRAIRIE LN	
City: ONALASKA	State: WI / Zip Code: 54650

County	Co. Permit #	Notification #	Completed
La Crosse	45	7039804801	12-11-2017

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ERIC LYSAKER	6735	

Address: LYSAKER WELL DRLG & SERV LLC, ONALASKA WI 54650

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ONALASKA

Fire # (if avail.): W7889

Street Address or Road Name and Number: W7889 PRAIRIE LN

Subdivision Name	Lot #	Block #
RIVERDELL	19	

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.9289 °N -91.2996 °W	GCD013

SW SE or Govt Lot #	Section	Township	Range
	23	17 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER SUPPLY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	101

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	G	SAND & GRAVEL	Surface	101

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PE STEEL .237 WALL 10.79# ASTMA53B WHEATLAND WELDED	Surface	98
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	STAINLESS STEEL 12 SLOT CONT.	98	101

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
37 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 10 GP M for 20 Hrs.
Pumping Method ?

11. Well Is
19 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EL		12-18-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		30
Building Drain - Sanitary		20	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-19-2018 Updated On: 04-30-2020 Review Status: