Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW012

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KURTZ, VIRGINIA			Phone #
Mailing Address: N7769 AMSTERDAM PRAIRE RD			
City: HOLMEN	State: WI	Zip Code: 54636	
County: La Crosse	Co. Permit #: 87	Notification #: 7036105901	Completed: 12-04-2017

Well Constructor (Business Name): ERIC LYSAKER	Lic. #: 6735	Facility ID # (Public Wells)	
Address: LYSAKER WELL DRLG & SERV LLC, ONALASKA WI 54650		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of HOLLAND

Fire # (if avail.): N7769

Street Address or Road Name and Number: N7769 AMSTERDAM PRAIRE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.0012 °N -91.3065 °W
Method Code: GCD013

SE	SW	Section	Township	Range
or Govt Lot #		26	18 N	8 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD SCREEN PLUGGED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	103

Upper Enlarged Drillhole
Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	G	SAND & GRAVEL	Surface	103

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PE STEEL .237 WALL 10.79# ASTMA53B WHEATLAND WELDED	Surface	100
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	STAINLESS STEEL 15 SLOT CONT.	100	103

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
65 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 10 GP M for 16 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EL		12-18-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Sewer - Building Sanitary		30
Building Drain - Sanitary		17	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-19-2018 Updated On: 04-30-2020 Review Status: