Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW013

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STROTT, DAWSON			Phone #
Mailing Address: N5415 ABBY RD			
City: ONALASKA	State: WI	Zip Code: 54650	

County	Co. Permit #	Notification #	Completed
La Crosse	73	7002229601	11-18-2017

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ERIC LYSAKER	6735	

Address: LYSAKER WELL DRLG & SERV LLC
ONALASKA WI 54650

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

3. Well serves 5 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ONALASKA

Fire # (if avail.)

Street Address or Road Name and Number
HOLLY DR

Subdivision Name	Lot #	Block #
STRAWBERRY COMMONS	3	9

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.5504 °N	-91.1447 °W			SCR002

NE	SW	Section	Township	Range
or Govt Lot #		29	17 N	7 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD SCREEN PLUGGED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	120

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	S	-	G	SAND & GRAVEL	Surface	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PE STEEL .237 WALL 10.79# ASTMA53B WHEATLAND WELDED	Surface	108
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	STAINLESS STEEL 15 SLOT CONT.	108	120

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
76 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 10 GP M for 16 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EL		12-18-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 02-19-2018 Updated On: 02-20-2018 Review Status: