Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW014

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WALTERS, CRAIG	Phone #
Mailing Address: 809 KELLY PL	
City: LA CROSSE	State: WI — Zip Code: 54603

County	Co. Permit #	Notification #	Completed
La Crosse	1	7073429201	01-08-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ERIC LYSAKER	6735	

Address: LYSAKER WELL DRLG & SERV LLC
ONALASKA WI 54650

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of CAMPBELL

Fire # (if avail.): 809

Street Address or Road Name and Number: 809 KELLY PL

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.8771 °N -91.2721 °W	SCR002

SE NE or Govt Lot #	Section	Township	Range
	12	16 N	8 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD POINT PLUGGED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	65

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	S	-	G	SAND & GRAVEL	Surface	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PE STEEL .237 WALL 10.79# ASTM A53B WHEATLAND WELDED	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	STAINLESS STEEL 15 SLOT CONT.	62	65

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 10 GP M for 10 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EL		01-27-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		15	Collector Sewer - San or Storm		80
			Sewer - Building Sanitary		28

Comment:

Created On: 02-19-2018 Updated On: 02-17-2020 Review Status: