

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW099		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707 Form 3300-077A						
Property Owner STANK, LEON				Phone # (920)591-0503		1. Well Location			Fire # (if avail.)			
Mailing Address 10284 KAPALIN RD						Town of BRAZEAU			10284			
City LENA				State WI Zip Code 54139		Street Address or Road Name and Number KAPALIN RD						
County Oconto		Co. Permit #		Notification # 7074922901		Completed 01-29-2018		Subdivision Name		Lot # Block #		
Well Constructor (Business Name) RAYMOND YOUNG JR				Lic. # 455		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 45.0444 °N -88.1382 °W		Method Code GPS008	
Address CHICKEN YOUNGS WELL DRILLING GILLET WI 54124-9587				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 25 30 N 19 E		2. Well Type Replacement				
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ? SHORT WATER				
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			
6		Surface		186		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
- - S -		SAND				Surface		35				
- - C S		SANDY CLAY				35		181				
- - N -		SANDSTONE				181		186				
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)				
6		WHEATLAND ASTMA53 WELDED				Surface		181				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)				
7. Grout or Other Sealing Material												
Method												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				
				Surface								
9. Static Water Level												
30 ft. below ground surface												
10. Pump Test												
Pumping level 60 ft. below surface												
Pumping at 20 GP M for 48 Hrs.												
Pumping Method ?												
11. Well Is												
24 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ? No												
Filled & Sealed Well(s) as needed? No												
PLUMBER												
13. Constructor / Supervisory Driller				Lic #		Date Signed						
RY						01-29-2018						
Drill Rig Operator				Lic or Reg #		Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 02-19-2018

Updated On: 08-16-2018

Review Status: