Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW101

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FRAMMES, TAMMY	Phone #: (920)598-1993
Mailing Address: 10498 QUARTERLINE RD	
City: GILLETT	State: WI — Zip Code: 54124

County	Co. Permit #	Notification #	Completed
Oconto		7080763401	02-23-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
RAYMOND YOUNG JR	455	

Address: CHICKEN YOUNGS WELL DRILLING, GILLETT WI 54124-9587

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GILLETT

Fire # (if avail.): 11480

Street Address or Road Name and Number: JOHN LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.8904 °N	-88.3368 °W			GPS008

SW NE or Govt Lot #	Section	Township	Range
	20	28 N	18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	175

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	30
-	-	C	S	SANDY CLAY	30	154
-	-	S	-	SAND	154	168
-	W	S	-	WATER & SAND	168	175

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTMA53 WELDED	Surface	172
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	1I SLOT STAINLESS STEEL	172	175

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
22 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NEW

13. Constructor / Supervisory Driller	Lic #	Date Signed
RY		02-23-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-17-2018 Updated On: 04-19-2018 Review Status: