

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW102		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SCHMACHER, MERV						Phone # (715)758-6210		1. Well Location				Fire # (if avail.)			
Mailing Address W4285 PORTER RD						Town of HARTLAND						W4285			
City BONDUEL						State WI		Zip Code 54107				Street Address or Road Name and Number PORTER RD			
County Shawano		Co. Permit #		Notification # 7140055801		Completed 04-17-2018		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) RAYMOND YOUNG JR				Lic. # 455		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7341 °N -88.4554 °W			Method Code GPS008		
Address CHICKEN YOUNGS WELL DRILLING GILLETT WI 54124-9587				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE NE		Section 17		Township 26 N		Range 17 E	
								or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.5				2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SAND					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		143		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit 6in. dia... Yes No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -				SAND				Surface		20					
- - C S				SANDY CLAY				20		30					
- - S -				SAND				30		35					
- - C S				SAND CLAY				35		85					
- - G C				STONE CLAY				85		120					
- - N -				SANDSTONE				120		143					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		WHEATLAND WELDED ASTMA 53				Surface		120							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
				Surface											
9. Static Water Level															
45 ft. below ground surface															
10. Pump Test															
Pumping level 55 ft. below surface															
Pumping at 15 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? Yes PLUMBER															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
RY						04-17-2018									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Animal Yard - Include Hutches		80
			Septic or Holding, or POWTS Tank		42

Comment:

Created On: 05-07-2018

Updated On: 11-19-2019

Review Status: