

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Landfill	>	1200
Building Drain - Sanitary	>	25	Sewer - Building Sanitary	>	30
Shoreline/Pool	>	50	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 12-21-2017

Updated On: 12-21-2017

Review Status: