Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW180

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GUYETTE, HAROLD			Phone #: (715)595-4608
Mailing Address: 27548 254TH ST			
City: HOLCOMBE	State: WI	Zip Code: 54745	
County: Chippewa	Co. Permit #: 171	Notification #: 6962089501	Completed: 11-03-2017
Well Constructor (Business Name): TRAVIS WILLMARTH	Lic. #: 6233	Facility ID # (Public Wells):	
Address: WILLMARTH WELL DRILLING HOLCOMBE WI 54745-9739		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3	

1. Well Location

Town of BIRCH CREEK				Fire # (if avail.): 27548
Street Address or Road Name and Number: 254TH ST				
Subdivision Name: BREEZY BAY			Lot #: 7	Block #: 1
Latitude / Longitude in Decimal Degree (DD): 45.24067 °N -91.15912 °W				Method Code: SCR002
NW SE or Govt Lot #:	Section: 19	Township: 32 N	Range: 6 W	

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: DRIVEN POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	28

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y	-	SAND & GRAVEL, CAVING, BROWN, SOFT	Surface	12
T	Q	Y	M	SILTY SAND & GRAVEL, CAVINTG, BROWN, SOFT	12	21
T	Q	Y	-	SAND & GRAVEL, CAVING, BROWN, SOFT	21	28

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD-ERW-A53 GR-B BLACK P.E. 6.625 O.D X .280 WALL	Surface	25
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	JOHNSON STAINLESS .010	24	28

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 16 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

17 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW		11-06-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	55
Shoreline/Pool	>	100

Type	Qualifier	Distance
Landfill	>	1200
Sewer - Building Sanitary	>	25
Septic or Holding, or POWTS Tank	>	55

Comment:

Created On: 12-21-2017 Updated On: 12-21-2017 Review Status: