Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW181

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MERRIMAN, TYLER & TIFFANY	Phone #: (715)595-4132
Mailing Address: N5771 730TH ST	
City: MENOMONIE	State: WI — Zip Code: 54751

County	Co. Permit #	Notification #	Completed
Dunn	11270	7005191802	11-25-2017

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
TRAVIS WILLMARTH	6233	

Address: WILLMARTH WELL DRILLING, HOLCOMBE WI 54745-9739

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of RED CEDAR

Fire # (if avail.): N5771

Street Address or Road Name and Number: 730TH ST

Subdivision Name	Lot #	Block #
	2	

Latitude / Longitude in Decimal Degree (DD): 44.8881 °N -91.79413 °W
Method Code: SCR002

SE SE or Govt Lot #	Section	Township	Range
	23	28 N	12 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	36
6	36	120

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 8in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	X	-	CLAY & SAND, NC, BROWN, SOFT	Surface	11
T	V	N	-	SANDSTONE, NC, TANISH, HARD	11	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD-ADTM-A53 GR-B BLACK P.E. 6.625 O.D. X .280 WALL	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 12 GP M for 5 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	36	9 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW		11-28-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100
Building Drain - Sanitary	>	25

Type	Qualifier	Distance
Landfill	>	1200
Sewer - Building Sanitary	>	25
Septic or Holding, or POWTS Tank	>	75

Comment:

Created On: 01-09-2018 Updated On: 01-09-2018 Review Status: