

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW182		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ROGGE, ROE						Phone # (715)271-6504		1. Well Location				Fire # (if avail.)	
Mailing Address 18571 CO HWY Q						Town of WOODMOHR						18589	
City BLOOMER						State WI		Zip Code 54724				Street Address or Road Name and Number CO HWY Q	
County Chippewa		Co. Permit # 202		Notification # 7005191801		Completed 12-01-2017		Subdivision Name CSM 4799				Lot # 1 Block #	
Well Constructor (Business Name) TRAVIS WILLMARTH				Lic. # 6233		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.11275 °N -91.52571 °W				Method Code SCR002	
Address WILLMARTH WELL DRILLING HOLCOMBE WI 54745-9739				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 6 30 N 9 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2		Hicap Well ? No Hicap Property ? No Hicap Potable ?							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) 6		From (ft.) Surface		To (ft.) 185		Upper Enlarged Drillhole Lower Open Bedrock		8. Geology					
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Geology Codes T V C G CLAY & ROCKS, NC, BROWN, SOFT T V C - CLAY, NC, BROWN, SOFT T V C N CLAY & SANDSTONE, NC, BROWN, SOFT - - N - SANDSTONE		Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) Surface 15 15 40 40 53 53 185			
6. Casing, Liner, Screen													
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly STD-ASTM-A53 GR-B BLACK P.E. 6.625 O.D. X .280 WALL				From (ft.) Surface		To (ft.) 53		9. Static Water Level 120 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material Method MOUNDED WHILE DRIVING													
Kind of Sealing Material GRANULAR BENTONITE		From (ft.) Surface		To (ft.) 20		# Sacks Cement S		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
13. Constructor / Supervisory Driller Lic # TW Date Signed 12-05-2017 Drill Rig Operator Lic or Reg # Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Landfill	>	1200
Building Drain - Sanitary	>	25	Sewer - Building Sanitary	>	35
			Septic or Holding, or POWTS Tank	>	75

Comment:

Created On: 01-09-2018

Updated On: 01-09-2018

Review Status: