

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW414		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BURR, TOM Phone # (715)542-4405						1. Well Location				Fire # (if avail.)							
Mailing Address 1462 HWY C						Town of ST GERMAIN				1462							
City ST GERMAIN State WI Zip Code 54558						Street Address or Road Name and Number CO HWY C											
County Vilas		Co. Permit #		Notification # 6995693101		Completed 11-14-2017		Subdivision Name			Lot #	Block #					
Well Constructor (Business Name) THOMAS F WRANIK				Lic. # 70	Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 45.9218 °N -89.549 °W			Method Code SCR002						
Address PO BOX 1266 EAGLE RIVER WI 54521-1266				Well Plan Approval #			SW NW	Section 30	Township 40 N	Range 8 E							
				Approval Date (mm-dd-yyyy)			or Govt Lot #										
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NITRATES (HIGH) Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		101		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - S G - - Y - - - M C - A S -		SAND & STONES SAND & GRAVEL SILT & CLAY COARSE SAND		Surface 36 88 93 93		36 88 93 101	
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		36 ft. below ground surface 10. Pump Test Pumping level 50 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?				12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
6		A53B WELDED M. LEAVITT 18.97LB SEC. 40 X 20				Surface		98									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		TEL. JOHNSON SS #10				98		101									
7. Grout or Other Sealing Material Method						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes											
Kind of Sealing Material		From (ft.)		To (ft.)								# Sacks Cement					
		Surface															
						13. Constructor / Supervisory Driller		Lic #		Date Signed							
						TW				11-14-2017							
						Drill Rig Operator		Lic or Reg #		Date Signed							
						PN				11-14-2017							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		72	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-27-2018

Updated On: 03-27-2018

Review Status: