

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW417		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner KWATERSKI BROS Phone # (715)479-5553						1. Well Location				Fire # (if avail.)		
Mailing Address 435 S US HWY 45						Town of LINCOLN				435		
City EAGLE RIVER State WI Zip Code 54521						Street Address or Road Name and Number S US HWY 45						
County Vilas		Co. Permit #		Notification # 7009403101		Completed 11-21-2017		Subdivision Name			Lot #	Block #
Well Constructor (Business Name) THOMAS F WRANIK				Lic. # 70	Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 45.8707 °N -89.1937 °W			Method Code SCR002	
Address PO BOX 1266 EAGLE RIVER WI 54521-1266				Well Plan Approval # Approval Date (mm-dd-yyyy)			SW	SW	Section	Township	Range	
							or Govt Lot #	12	39	N	10 E	
Hicap Permanent Well #		Common Well #		Specific Capacity			2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? QUALITY Construction Type Drilled					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock					
6	Surface	247	Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
- - S -		SAND				Surface		48				
- - C -		CLAY				48		110				
- - Y C		SAND, GRAVEL, CLAY				110		112				
K - G -		BLACK ROCK				112		220				
R - Q -		RED GRANITE ROCK				220		247				
6. Casing, Liner, Screen												
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)						
6	A53B WELDED M. LEAVITT 18.97LB SEC. 40 X 20				Surface	112						
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)						
7. Grout or Other Sealing Material												
Method												
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement							
			Surface									
9. Static Water Level												
8 ft. below ground surface												
10. Pump Test												
Pumping level 225 ft. below surface												
Pumping at 2.2 GP M for 24 Hrs.												
Pumping Method ?												
11. Well Is												
12 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ?												
Filled & Sealed Well(s) as needed? Yes												
13. Constructor / Supervisory Driller												
Lic # Date Signed												
TW 11-21-2017												
Drill Rig Operator												
Lic or Reg # Date Signed												
PN 11-21-2017												

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 03-27-2018

Updated On: 03-27-2018

Review Status: