Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW417

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KWATERSKI BROS	Phone #: (715)479-5553
Mailing Address: 435 S US HWY 45	
City: EAGLE RIVER	State: WI Zip Code: 54521
County: Vilas	Co. Permit #:
Notification #: 7009403101	Completed: 11-21-2017
Well Constructor (Business Name): THOMAS F WRANIK	Lic. #: 70
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: PO BOX 1266 EAGLE RIVER WI 54521-1266	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of LINCOLN	Fire # (if avail.): 435
Street Address or Road Name and Number: S US HWY 45	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 45.8707 °N -89.1937 °W	Method Code: SCR002
SW SW or Govt Lot #:	Section: 12 Township: 39 N Range: 10 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: QUALITY

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	247

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	48
-	-	C	-	CLAY	48	110
-	-	Y	C	SAND, GRAVEL, CLAY	110	112
K	-	G	-	BLACK ROCK	112	220
R	-	Q	-	RED GRANITE ROCK	220	247

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B WELDED M. LEAVITT 18.97LB SEC. 40 X 20	Surface	112
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 225 ft. below surface

Pumping at 2.2 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW		11-21-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
PN		11-21-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 03-27-2018 Updated On: 10-15-2026 Review Status: