Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW479

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: WEINREICH, BRIAN		Phone #: (262)483-1210
Mailing Address: 678 HWY H		
City: FREDONIA	State: WI	Zip Code: 53021

County	Co. Permit #	Notification #	Completed
Washington		7231674101	06-19-2018

Well Constructor (Business Name): LAABS WELL DRILLING INC	Lic. #: 560	Facility ID # (Public Wells):
Address: N160W20373 FOX CREEK DR JACKSON WI 53037		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2

1. Well Location

Town of FREDONIA | Fire # (if avail.): 678

Street Address or Road Name and Number: HWY H

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.4983 °N -88.0695 °W | Method Code: GPS008

SW SE or Govt Lot #	Section	Township	Range
	14	12 N	20 E

2. Well Type Replacement

of previous unique well # | constructed in

Reason for replaced or reconstructed well ?: DRY WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	197

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	C-CLAY G-W/GRAVEL/STONES	Surface	27
		P		P-HARDPAN	27	86
		S		S-SAND	86	107
		C	S	C-CLAY S-SANDY	107	117
		L		L-LIMESTONE/DOLOMITE	117	197

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.91# PER-FT. WELDED JT. P.END STEEL A-53 TIAWAN	Surface	117
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is

12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface	117	3.5 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RL	472	06-19-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 08-06-2018 Updated On: 07-08-2019 Review Status: APPROVED