

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW479		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner WEINREICH, BRIAN						Phone # (262)483-1210		1. Well Location				Fire # (if avail.)					
Mailing Address 678 HWY H						Town of FREDONIA						678					
City FREDONIA						State WI		Zip Code 53021				Street Address or Road Name and Number HWY H					
County Washington		Co. Permit #		Notification # 7231674101		Completed 06-19-2018		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) LAABS WELL DRILLING INC				Lic. # 560		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4983 °N -88.0695 °W			Method Code GPS008				
Address N160W20373 FOX CREEK DR JACKSON WI 53037				Well Plan Approval #		SW SE		Section 14		Township 12 N		Range 20 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2		2. Well Type Replacement											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? DRY WELL									
						Hicap Property ? No											
						Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		197		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				C G C-CLAY G-W/GRAVEL/STONES P P-HARDPAN S S-SAND C S C-CLAY S-SANDY L L-LIMESTONE/DOLOMITE		Surface 27 86 107 117 117		27 86 107 117 197			
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface		12 in. above grade					
6		18.91# PER-FT. WELDED JT. P.END STEEL A-53 TIAWAN				Surface		117		10. Pump Test Pumping level 100 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Airlift		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes							
7. Grout or Other Sealing Material Method												13. Constructor / Supervisory Driller		Lic #		Date Signed	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		RL		472		06-19-2018			
CRUMBLES				Surface		117		3.5 S		Drill Rig Operator		Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 08-06-2018

Updated On: 07-08-2019

Review Status: APPROVED