

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW482		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RIVEREDGE NATURE CENTER						Phone # (920)287-9670		1. Well Location				Fire # (if avail.)							
Mailing Address 4400 HAWTHORNE DR								Town of SAUKVILLE											
City NEWBURG						State WI		Zip Code 53080											
County Ozaukee		Co. Permit #		Notification # 7430335201		Completed 02-22-2019		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) LAABS WELL DRILLING INC						Lic. # 560		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4367 °N -88.0271 °W		Method Code GPS008					
Address N160W20373 FOX CREEK DR JACKSON WI 53037						Well Plan Approval #		NW NE		Section 7		Township 11 N		Range 21 E					
								or Govt Lot #											
Approval Date (mm-dd-yyyy)						2. Well Type New Well		of previous unique well # constructed in											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ?											
3. Well serves 1 # of NATURE CENTER						Hicap Well ? No		Construction Type Drilled											
Non-community						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) 6		From (ft.) Surface		To (ft.) 215		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
						No Rotary - Mud Circulation		No		C G		C-CLAY G-W/GRAVEL/STONES		Surface		15			
						No Rotary - Air		Yes		S		S-SAND		15		50			
						No Rotary - Air & Foam		No		B L		B-BROKEN L-LIMESTONE/DOLOMITE		50		55			
						No Drill-Through Casing Hammer				L		L-LIMESTONE/DOLOMITE		55		215			
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				12 in. above grade					
6		18.97 # PER FT WELDED JT PE A-53 WHEATLAND				Surface		55		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface				Disinfected ? Yes					
										Pumping at 10 GP M for 3 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Yes							
Method																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				Filled & Sealed Well(s) as needed?				No					
CRUMBLES		Surface		55		2 S													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RL				472		02-22-2019	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	55

Comment:

Created On: 03-15-2019

Updated On: 03-19-2019

Review Status: APPROVED