Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW482

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RIVEREDGE NATURE CENTER			Phone #: (920)287-9670
Mailing Address: 4400 HAWTHORNE DR			
City: NEWBURG	State: WI	Zip Code: 53080	
County: Ozaukee	Co. Permit #:	Notification #: 7430335201	Completed: 02-22-2019

Well Constructor (Business Name): LAABS WELL DRILLING INC	Lic. #: 560	Facility ID # (Public Wells):	
Address: N160W20373 FOX CREEK DR JACKSON WI 53037		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

1. Well Location
Town of SAUKVILLE
Fire # (if avail.)
Street Address or Road Name and Number: 4400 HAWTHORNE
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD): 43.4367 °N -88.0271 °W
Method Code: GPS008
NW NE or Govt Lot #: | Section: 7 | Township: 11 N | Range: 21 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of NATURE CENTER
Non-community
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	215

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	C-CLAY G-W/GRAVEL/STONES	Surface	15
		S		S-SAND	15	50
	B	L		B-BROKEN L-LIMESTONE/DOLOMITE	50	55
		L		L-LIMESTONE/DOLOMITE	55	215

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 # PER FT WELDED JT PE A-53 WHEATLAND	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ? Test Pump

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface	55	2 S

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RL	472	02-22-2019
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	55

Comment:

Created On: 03-15-2019 Updated On: 03-19-2019 Review Status: APPROVED