

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW855		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WEBER, ABE & TRACY						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N15749 HARRIS RD						Town of TREMPPEALEAU						N1575			
City TREMPPEALEAU						State WI		Zip Code 54661				Street Address or Road Name and Number HARRIS RD			
County Trempealeau		Co. Permit # 768		Notification # 7037504201		Completed 01-17-2018		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) WAYNE HOLLER				Lic. # 4668		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0672 °N -91.4616 °W				Method Code GPS008	
Address HOLLER PLUMBING & WELL DRILLING LA CROSSE WI 54601-2935				Well Plan Approval #				SE NW		Section 4		Township 18 N		Range 9 W	
				Approval Date (mm-dd-yyyy)				or Govt Lot #		4		18 N		9 W	
Hicap Permanent Well #				Common Well #		Specific Capacity 1				2. Well Type New Well					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No				of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
4		Surface		105		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 4in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				No					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
4		ASTM A53 SCH40 .237 WALL MARUICHI LEAVITT USA PLAIN END WELD				Surface		102							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) T N S M TOPSOIL-SAND SILT Surface 4 T S S - MIX SAND 4 56 T A S - MED SAND-COARSE 56 63 T N S - FINE-MIX SAND 63 84 T M X - MED SAND-THIN CLAY 84 105					
4		ALLOY STEEL 10 SLOT				102		105							
7. Grout or Other Sealing Material															
Method MOUNDED BENTONITE															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		9. Static Water Level 48 ft. below ground surface					
CRUMBLES #8				Surface				4 S							
10. Pump Test															
Pumping level 60 ft. below surface Pumping at 12 GP M for 2 Hrs. Pumping Method ?															
11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE EXIST															
13. Constructor / Supervisory Driller															
WH															
Drill Rig Operator															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Landfill	>	1200
Building Drain - Sanitary		26	Sewer - Building Sanitary		32
			Septic or Holding, or POWTS Tank		55

Comment:

Created On: 02-19-2018

Updated On: 07-31-2019

Review Status: