

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YW858		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner MCCOY, DOUG						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address N6735 EGGENS COULEE RD						Town of GREENFIELD																	
City WEST SALEM						State WI		Zip Code 54669															
County La Crosse		Co. Permit # 53		Notification # 7087459002		Completed 03-16-2018		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) WAYNE HOLLER				Lic. # 4668		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4701 °N -91.0531 °W				Method Code GPS008									
Address HOLLER PLUMBING & WELL DRILLING LA CROSSE WI 54601-2935				Well Plan Approval #		SW SW		Section 10		Township 15 N		Range 6 W											
				Approval Date (mm-dd-yyyy)		or Govt Lot #																	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		2. Well Type New Well				of previous unique well # constructed in													
Reason for replaced or reconstructed well ?																							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No				Construction Type Drilled													
Heat Exchange ___ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10.5		Surface		4		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing 10in. dia Removed? 4depth ft. (If NO explain on back side)				Yes Yes		R V C G		RED CLAY WITH FLINT		Surface		36					
9.5		4		280								Y H L L		LIMESTONE		36		147					
6		280		515								Y H H H		HARD SHALE		147		215					
												Y H N N		HARD SANDROCK		215		238					
												G H H H		HARD SHALE		238		408					
								I H N N		HARD SANDSTONE		408		515									
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		432 ft. below ground surface				28 in. above grade									
6		ASTM A53B .280 WALL WHEATLAND USA PLAIN END WELD				Surface		280		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 500 ft. below surface				Disinfected ? Yes									
										Pumping at 10 GP M for 14 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method PUMPED TREMIE PIPE														Filled & Sealed Well(s) as needed? No									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		NONE EXIST													
NEAT CEMENT GROUT				Surface		280		90 S															
13. Constructor / Supervisory Driller														Lic #		Date Signed							
WH																03-25-2018							
Drill Rig Operator														Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Landfill	>	1200
Building Drain - Sanitary		35	Sewer - Building Sanitary		52
			Septic or Holding, or POWTS Tank		48

Comment:

Created On: 04-17-2018

Updated On: 04-19-2018

Review Status: