Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW891

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHWARTZ, RON	Phone #: (715)324-5370
Mailing Address: W8302 WECKERLE RD	
City: PEMBINE	State: WI / Zip Code: 54156
County: Marinette	Co. Permit #:
Notification #: 7079475701	Completed: 02-07-2018
Well Constructor (Business Name): DOUGLAS J MORIN	Lic. #: 6311
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: MORIN AND JOHNSON WELL DRLG & PUMP NIAGARA WI 54151	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.9	

1. Well Location

Town of PEMBINE	Fire # (if avail.): W8302
Street Address or Road Name and Number: WECKERLE	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 45.5885 °N -88.0099 °W	Method Code: GCD013
NE SW or Govt Lot #:	Section: 16 / Township: 36 N / Range: 20 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: POINT PROBLEMS

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	9
6	9	43

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - S -	SAND	Surface	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTMA53B EXCEL .280W 18.97 LB/FT WELDED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
8	23 SS TELESCOPING #15	40	43

9. Static Water Level

3 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	40	2 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

WELL PIT TO BE ABANDONED IN SPRING

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJM		02-19-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60
Building Drain - Sanitary	>	35

Type	Qualifier	Distance
Shoreline/Pool	>	50
Sewer - Building Sanitary	>	35
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 03-27-2018 Updated On: 10-22-2019 Review Status: