Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YW895

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BUTTERFIELD, HOWARD	Phone #: (715)251-4548
Mailing Address: PO BOX 186	
City: NIAGARA	State: WI — Zip Code: 54151
County: Marinette	Co. Permit #:
Notification #: 7142063701	Completed: 04-23-2018
Well Constructor (Business Name): DOUGLAS J MORIN	Lic. #: 6311
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: MORIN AND JOHNSON WELL DRLG & PUMP NIAGARA WI 54151	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of NIAGARA				Fire # (if avail.): N2237
Street Address or Road Name and Number: N22370 SCHINDLER RD				
Subdivision Name:			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 45.7626 °N -87.979 °W				Method Code: GCD013
SE NE or Govt Lot #:	Section: 15	Township: 38 N	Range: 20 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of GARAGE
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	60
6	60	200

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation ..... — No
- No / Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	G	SAND/STONES	Surface	23
-	N	S	G	FINE SAND, BOULDERS	23	34
-	N	C	S	FINE CLAY SAND	34	57
-	-	Q	-	GRANITE	57	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTMA53B IPSCO .280W 18.97LB/FT WELDED	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MUD ROTARY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	60	3 S

9. Static Water Level
60 ft. below ground surface

10. Pump Test
Pumping level 180 ft. below surface
Pumping at 3 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJM		04-25-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Sewer - Building Sanitary	>	50
Building Drain - Sanitary	>	50	Septic or Holding, or POWTS Tank	>	70

Comment:

Created On: 05-07-2018 Updated On: 10-22-2019 Review Status: