

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YX201		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner HILL CONSTRUCTION						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 15988 US HWY 63						Town of HAYWARD						16455									
City HAYWARD						State WI		Zip Code 54843				Street Address or Road Name and Number STONEWOOD CT									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Sawyer				7075420401		01-28-2018															
Well Constructor (Business Name) JEREMY R BEECROFT				Lic. # 6457		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.0057 °N -91.518 °W				Method Code GPS008							
Address JEREMY BEECROFT WELL DRLG & PUMP REPAIR SPOONER WI 54801				Well Plan Approval #				SE NW		Section 29		Township 41 N		Range 9 W							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 1.4				2. Well Type New Well				of previous unique well #		constructed in					
3. Well serves 1 # of				Hicap Well ? No				Reason for replaced or reconstructed well ?				Construction Type Drilled									
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		92		Yes Rotary - Mud Circulation No						- - Y G		SAND, GRAVEL & STONES		Surface		40			
						Rotary - Air						- A G C		COARSE GRAVEL, ROCK & CLAY		40		82			
						Rotary - Air & Foam						- A G -		COARSE GRAVEL		82		92			
						Drill-Through Casing Hammer															
						Reverse Rotary															
						Cable-tool Bit ___ in. dia...															
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		42 ft. below ground surface				18 in. above grade							
5		SDR17 PVC CASING CEMENT SOLVENT WELD FORMATION STABILIZER				Surface		87		10. Pump Test				Developed ? Yes							
										Pumping level 70 ft. below surface				Disinfected ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 40 GP M for 1 Hrs.				Capped ? Yes							
5		15 SLOT S.S. SCREEN				87		92		Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
EZ SEAL				Surface		80		8 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														NB				02-27-2018			
														Drill Rig Operator		Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Septic or Holding, or POWTS Tank		90

Comment:

Created On: 03-27-2018

Updated On: 04-05-2018

Review Status: