Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YX203

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CHASE, RYAN			Phone #
Mailing Address: 6322 OAKES AVE			
City: SUPERIOR	State: WI	Zip Code: 54880	
County: Douglas	Co. Permit #:	Notification #: 7099385803	Completed: 03-08-2018

Well Constructor (Business Name): JEREMY R BEECROFT	Lic. #: 6457	Facility ID # (Public Wells):	
Address: JEREMY BEECROFT WELL DRLG & PUMP REPAIR SPOONER WI 54801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.9	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of WASCOTT

Fire # (if avail.): 16345

Street Address or Road Name and Number: S CAROL

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): 46.174 °N -91.7743 °W		Method Code: GPS008	
SW SW or Govt Lot #	Section: 29	Township: 43 N	Range: 11 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	133

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	A	Y	-	COARSE SAND & GRAVEL	Surface	80
-	A	Y	C	COARSE SAND, GRAVEL & CLAY	80	125
-	A	S	-	COARSE SAND	125	133

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17 PVC CASING CEMENT SOLVENT WELD FORMATION STABILIZER	Surface	128
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	15 SLOT SS SCREEN	128	133

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	125	11 S

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 100 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB		03-21-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		32

Comment:

Created On: 04-17-2018 Updated On: 06-25-2020 Review Status: