Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YX204

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: COLES, LYNN	Phone #
Mailing Address: 28898 KILKARE RD	
City: DANBURY	State: WI — Zip Code: 54830
County: Burnett	Co. Permit #: — Notification #: 7099385801 — Completed: 03-09-2018
Well Constructor (Business Name): JEREMY R BEECROFT	Lic. #: 6457 — Facility ID # (Public Wells):
Address: JEREMY BEECROFT WELL DRLG & PUMP REPAIR, SPOONER WI 54801	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.8

1. Well Location

Town of SCOTT	Fire # (if avail.): 28898
Street Address or Road Name and Number: KILKARE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9625 °N -92.1468 °W	Method Code: GPS008
NE SW or Govt Lot #:	Section: 7 — Township: 40 N — Range: 14 W

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
IRON IN OLD WELL
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	198

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	110
-	J	G	-	COARSE GRAVEL & IRON	110	150
-	-	P	C	HARDPAN CLAY BITS	150	190
-	A	S	-	COARSE SAND	190	198

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17 PVC CASING CEMENT SOLVENT WELD FORMATION STABILIZER	Surface	193
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	18 SLOT S.S. SCREEN	193	198

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	190	15 S

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 40 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes
WE WILL BE ABANDONING THE OLD POINT IN MAY

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB		03-21-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100

Type	Qualifier	Distance
Shoreline/Pool		140
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 04-17-2018 Updated On: 06-30-2020 Review Status: