

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YX204		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner COLES, LYNN					Phone #		1. Well Location Fire # (if avail.) 28898				
Mailing Address 28898 KILKARE RD					Town of SCOTT						
City DANBURY				State WI		Zip Code 54830		Street Address or Road Name and Number KILKARE RD			
County Burnett		Co. Permit #		Notification # 7099385801		Completed 03-09-2018		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) JEREMY R BEECROFT				Lic. # 6457		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.9625 °N -92.1468 °W		Method Code GPS008	
Address JEREMY BEECROFT WELL DRLG & PUMP REPAIR SPOONER WI 54801				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 7 40 N 14 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? IRON IN OLD WELL			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8		3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes Hicap Well ? No Hicap Property ? No Hicap Potable ? No Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...	
8.75		Surface		198		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				- - Y - SAND & GRAVEL Surface 110 - J G - COARSE GRAVEL & IRON 110 150 - - P C HARDPAN CLAY BITS 150 190 - A S - COARSE SAND 190 198	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
		5 SDR17 PVC CASING CEMENT SOLVENT WELD FORMATION STABILIZER				Surface		193			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
		5 18 SLOT S.S. SCREEN				193		198			
7. Grout or Other Sealing Material											
Method											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? Yes WE WILL BE ABANDONING THE OLD POINT IN MAY	
EZ SEAL				Surface		190		15 S			
13. Constructor / Supervisory Driller Lic # Date Signed JB 03-21-2018 Drill Rig Operator Lic or Reg # Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Shoreline/Pool		140
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 04-17-2018

Updated On: 06-30-2020

Review Status: