Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YX226

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SIMONETS, SCOTT	Phone #: (920)360-9696
Mailing Address: 4641 POINT COMFORT LN	
City: GREEN BAY	State: WI — Zip Code: 54311
County: Brown	Co. Permit #:
Notification #: 6931574701	Completed: 09-08-2017
Well Constructor (Business Name): GERALD L COOPER	Lic. #: 6211
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 5050 BROWN RD LITTLE SUAMICO WI 54141	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.5	

1. Well Location

Town of GREEN BAY			Fire # (if avail.): 4641
Street Address or Road Name and Number: POINT COMFORT LN			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.6182 °N -87.8478 °W			Method Code: GPS008
NE NE or Govt Lot #	Section: 29	Township: 25 N	Range: 22 E

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: CASING ROTTEN
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	4
6	4	44

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 8in. dia... — Yes
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S -	SAND, CAVING, TAN, SOFT	Surface	8
T S C -	CLAY, NONCAVING, TAN, SOFT	8	25
G H C G	CLAY & GRAVEL, HARD, GREY	25	42.5
T H L -	LIMESTONE, NONCAVING HARD TAN	42.5	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LB PER FOOT ASTM A53 EXL TUBE WELDED	Surface	42.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENSEAL	Surface	42.5	1 S

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 16 ft. below surface
Pumping at 15 GP M for 12 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
DANS PUMP WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
GLO		09-20-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		50	Shoreline/Pool		26
Collector Sewer - San or Storm		77	Sewer - Building Sanitary		52

Comment: 11/14/17: AFTER MAP REVIEW, I CORRECTED LAT/LONG TO MATCH ADDRESS & PLSS SUBMITTED. DLR OWNER CALLED ON 041918 & INDICATED DANS PUMP WILL F&S WHEN SNOW IS GONE.

Created On: 10-18-2017 Updated On: 11-21-2019 Review Status: