

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YX393		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MASTERJOHN, MIKE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address PO BOX 144						Town of SWISS						4646							
City SPOONER						State WI		Zip Code 54801				Street Address or Road Name and Number 4646 LAKE 26 RD							
County Burnett		Co. Permit #		Notification # 6949429901		Completed 09-27-2017		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) JEFFREY J RUTHERFORD				Lic. # 6202		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.0137 °N -92.2177 °W				Method Code GPS008					
Address H2O WELL & PUMP TREGO WI 54888				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SE		Section 22		Township 41 N		Range 15 W					
								or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7				2. Well Type Replacement of previous unique well # constructed in									
Reason for replaced or reconstructed well ? LOW VOLUME SANDPOINT																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
4		Surface		52								T M S - MED. BROWN SAND		Surface		30			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 3.75in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						T N S - MED. TO FINE BROWN SAND		30		52			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		33 ft. below ground surface				20 in. above grade					
4		ASTMA 53 SA53 4.5 X .237 20' EXLTUBE WELDED				Surface		49		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 44 ft. below surface Pumping at 8 GP M for 12 Hrs. Pumping Method ?									
3		STAINLESS 10 SLOT				49		52											
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
				Surface															
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												JR						10-16-2017	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		57	Septic or Holding, or POWTS Tank		36

Comment:

Created On: 12-21-2017

Updated On: 12-21-2017

Review Status: