Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YX395

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BAKKE, GREG			Phone #
Mailing Address: 6335 E PERSONS LANDING RD			
City: WASCOTT	State: WI	Zip Code: 54890	
County: Douglas	Co. Permit #:	Notification #: 6983725001	Completed: 10-30-2017

Well Constructor (Business Name): JEFFREY J RUTHERFORD	Lic. #: 6202	Facility ID # (Public Wells):	
Address: H20 WELL & PUMP TREGO WI 54888		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of WASCOTT

Fire # (if avail.): 6335

Street Address or Road Name and Number: 6335 E PERSONS LANDING RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 46.1845 °N -91.9687 °W
Method Code: OTH001

NE	NE	Section	Township	Range
or Govt Lot #		27	43 N	13 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
5P IN PIT & NONCOMPLYING & LOW VOLUME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	32

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 3.75in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - S G	BROWN SAND & SMALL ROCK	Surface	32

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTMA53 SA53 4-5 X .237 20' EXLTUBE WELDED	Surface	28
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	STAINLESS 10 SLOT	28	32

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
11 ft. below ground surface

10. Pump Test
Pumping level 18 ft. below surface
Pumping at 12 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR		11-17-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Septic or Holding, or POWTS Tank		34

Comment:

Created On: 01-09-2018 Updated On: 06-25-2020 Review Status: