

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YX772		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SIMPSON, ROBERT						Phone # (608)475-1165		1. Well Location				Fire # (if avail.)									
Mailing Address 1710 HWY 14 E						Town of RICHLAND						Street Address or Road Name and Number									
City RICHLAND CENTER						State WI		Zip Code 53581				24334 CO HWY A									
County Richland		Co. Permit #		Notification # 7038099601		Completed 12-07-2017		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) CORPIAN WELL DRILLING INC				Lic. # 61		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.3723 °N -90.4028 °W				Method Code GPS008							
Address 4747 OLD C RD BOSCOBEL WI 53805				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 5 10 N 1 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
						Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		28										- - I -		DIRT		Surface		1	
6		28		100		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 28depth ft. (If NO explain on back side)								- - C -		CLAY		1		22	
														- - G U		MUD & GRAVEL		22		68	
														I H N -		HARD WHITE SANDROCK		68		100	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		31 ft. below ground surface				26 in. above grade							
6		NEW BLACK STEEL PLAIN END WHEATLAND ASTM-A-53-B				Surface		72		10. Pump Test Pumping level 80 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method TREMIE-PUMPED														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed					
NEAT CEMENT				Surface		28		36 S		MDB						12-07-2017					
										Drill Rig Operator				Lic or Reg #		Date Signed					
										RK						12-07-2017					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	150	Septic or Holding, or POWTS Tank	>	75

Comment:

Created On: 01-09-2018

Updated On: 01-09-2018

Review Status: