Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YX773

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: AUGELLI, ANTHONY			Phone #: (608)852-4469
Mailing Address: 28351 ST HWY 80			
City: RICHLAND CENTER	State: WI	Zip Code: 53581	
County: Richland	Co. Permit #:	Notification #: 6993768601	Completed: 12-06-2017

1. Well Location

Town of ORION

Fire # (if avail.):

Street Address or Road Name and Number: 22102 ST HWY 60

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): CORPIAN WELL DRILLING INC	Lic. #: 61	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 43.2024 °N -90.4273 °W
Address: 4747 OLD C RD, BOSCOBEL WI 53805		Well Plan Approval #:	Method Code: GPS008
		Approval Date (mm-dd-yyyy):	

NW	NW	Section	Township	Range
or Govt Lot #		6	8 N	1 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: OLD SAND PT. IN BASEMENT

Construction Type: Drilled

Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	63
6	63	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Yes / No — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 16depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	DIRT	Surface	1
-	S	Y	-	LOOSE SAND & GRAVEL	1	16
-	-	H	-	SHALE	16	27
-	-	N	-	SANDROCK	27	39
I	H	N	-	HARD WHITE SANDROCK	39	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PLAIN END WHEATLAND ASTM-A-53-B	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	63	27 S

9. Static Water Level

39 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

36 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
MDB		12-06-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RK		12-06-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 01-09-2018 Updated On: 01-09-2018 Review Status: