Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YX774

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	Phone #
SCHWARZMANN, GEORGE	(608)762-5875

Mailing Address: 21791 SANDHILL RD

City: PLATTEVILLE | State: WI | Zip Code: 53818

County	Co. Permit #	Notification #	Completed
Lafayette		7035659301	12-05-2017

Well Constructor (Business Name): CORPIAN WELL DRILLING INC | Lic #: 61 | Facility ID # (Public Wells)

Address: 4747 OLD C RD, BOSCOBEL WI 53805

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.2

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.)

Town of BELMONT

Street Address or Road Name and Number: 21791 SANDHILL RD

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 42.8099 °N -90.3583 °W | Method Code: GPS008

SW NE or Govt Lot #	Section	Township	Range
	22	4 N	1 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	147
6	147	220

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Yes / No — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	DIRT	Surface	1
-	-	C	-	CLAY	1	10
-	-	L	-	LIMEROCK	10	78
-	-	N	-	SANDROCK	78	220

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PLAIN END WHEATLAND ASTM-A-53-B	Surface	147
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	147	54 S

9. Static Water Level
147 ft. below ground surface

10. Pump Test
Pumping level 200 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
38 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
MDB		12-05-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RK		12-05-2017

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-09-2018 Updated On: 09-04-2019 Review Status: