

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YX774		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SCHWARZMANN, GEORGE						Phone # (608)762-5875		1. Well Location				Fire # (if avail.)							
Mailing Address 21791 SANDHILL RD						Town of BELMONT													
City PLATTEVILLE						State WI		Zip Code 53818											
County Lafayette		Co. Permit #		Notification # 7035659301		Completed 12-05-2017		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) CORPIAN WELL DRILLING INC				Lic. # 61		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8099 °N -90.3583 °W				Method Code GPS008					
Address 4747 OLD C RD BOSCOBEL WI 53805				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 22 4 N 1 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		147		Rotary - Mud Circulation				- - I -		DIRT		Surface		1			
6		147		220		<u>Yes</u> Rotary - Air <u>Yes</u> <u>Yes</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 10depth ft. (If NO explain on back side)				- - C -		CLAY		1		10			
										- - L -		LIMEROCK		10		78			
										- - N -		SANDROCK		78		220			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		147 ft. below ground surface				38 in. above grade					
6		NEW BLACK STEEL PLAIN END WHEATLAND ASTM-A-53-B				Surface		147		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 200 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material Method TREMIE PUMPED												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement						13. Constructor / Supervisory Driller				Lic #		Date Signed	
NEAT CEMENT		Surface		147		54 S						MDB						12-05-2017	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												RK						12-05-2017	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-09-2018

Updated On: 09-04-2019

Review Status: