Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YX775

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ABT, ANDREW & DACHIA			Phone #: (608)606-1454
Mailing Address: S5389 EAGLE DR			
City: VIROQUA	State: WI	Zip Code: 54665	
County: Vernon	Co. Permit #:	Notification #: 7035658001	Completed: 12-04-2017

1. Well Location

Town of JEFFERSON

Fire # (if avail.)

Street Address or Road Name and Number: S2967 SEBION RD

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
CORPIAN WELL DRILLING INC	61	

Latitude / Longitude in Decimal Degree (DD): 43.6251 °N -90.9373 °W

Method Code: GPS008

Well Plan Approval #:

NW or Govt Lot #	NE	Section	Township	Range
		11	13 N	5 W

Address: 4747 OLD C RD, BOSCOBEL WI 53805

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	273
6	273	380

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Yes / No — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 8depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	DIRT	Surface	1
-	-	C	-	CLAY	1	8
-	C	L	-	LIMEROCK & CREV.	8	166
-	-	N	-	SANDROCK	166	213
-	-	H	-	SHALE	213	267
-	H	H	-	HARD SHALE	267	380

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PLAIN END WHEATLAND ASTM-A-53-B	Surface	273
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

233 ft. below ground surface

10. Pump Test

Pumping level 360 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	273	109 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MDB		12-04-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RK		12-04-2017

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 01-09-2018 Updated On: 01-09-2018 Review Status: