Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YX806

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FARAH, BOB	Phone #
Mailing Address: 3401 MEADOW GREEN RD	
City: DANBURY	State: WI — Zip Code: 54830
County: Burnett	Co. Permit #: — Notification #: 7037040601 — Completed: 12-05-2017
Well Constructor (Business Name): DAVID M BEECROFT	Lic. #: 6242 — Facility ID # (Public Wells):
Address: W8760 CTY J, SHELL LAKE WI 54871	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 6

1. Well Location

Town of SCOTT	Fire # (if avail.): 3401
Street Address or Road Name and Number: MEADOW GREEN RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9594 °N -92.1568 °W	Method Code: GCD013
SW SW or Govt Lot #:	Section: 7 — Township: 40 N — Range: 14 W

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	248

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes — Rotary - Mud Circulation ..... — No
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	100
-	H	Z	-	CEMENT CLAY & GRAVEL	100	235
Y	-	Y	-	YELLOW SAND & GRAVEL	235	248

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	CRESTLINE PVC SDR21 SOLVENT JOINT	Surface	240
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	STAINLESS TELESCOPE 20 SLOT	240	248

9. Static Water Level
33 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
QUICK GROUT	Surface	235	27 S
RED FLINT #30	235	248	12 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DMB		12-05-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		127

Comment: 1/18/18: AFTER MAP REVIEW, I CORRECTED LAT/LONG. DLR

Created On: 01-09-2018 Updated On: 06-30-2020 Review Status: