Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY080

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NEHLS, RICK			Phone #: (715)678-2946
Mailing Address: N1381 CO RD E			
City: MEDFORD	State: WI	Zip Code: 54451	
County: Price	Co. Permit #:	Notification #: 7101315803	Completed: 03-12-2018

Well Constructor (Business Name): RONALD A KOMAREK SR	Lic. #: 610	Facility ID # (Public Wells):	
Address: KOMAREK WELL DRILLING, OGEMA WI 54459		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.3	

1. Well Location

Town of LAKE			Fire # (if avail.): N1671
Street Address or Road Name and Number: LAKESHORE DR			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.9754 °N -90.5121 °W			Method Code: GPS008
SE NE or Govt Lot #:	Section: 5	Township: 40 N	Range: 1 W

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of CAMPER
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	51

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	S	-	CAVING CLEAN SAND	Surface	21
-	-	S	U	DIRTY SAND	21	39
-	-	Y	-	SAND & GRAVEL	39	51

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5.563	ASTM A53B 14.62# WELD JT WHEATLAND	Surface	47
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	15 SLOT SS ALLOY WORKS	47	51

7. Grout or Other Sealing Material

Method NONE NEEDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
2 ft. below ground surface

10. Pump Test
Pumping level 10 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
31 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RK		03-15-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		56	Septic or Holding, or POWTS Tank		57

Comment:

Created On: 03-27-2018 Updated On: 03-27-2018 Review Status: