Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY081

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAKOVSKY, BERNIE	Phone #: (715)428-2782
Mailing Address: N4928 CHICAGO AVE	
City: PRENTICE	State: WI — Zip Code: 54556

County	Co. Permit #	Notification #	Completed
Price		7101315801	03-13-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
RONALD A KOMAREK SR	610	

Address: KOMAREK WELL DRILLING, OGEMA WI 54459

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of GEORGETOWN

Fire # (if avail.): W1163

Street Address or Road Name and Number: LIBERTY LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)		Method Code
45.5675 °N	-90.656 °W	GPS008

SW SW or Govt Lot #	Section	Township	Range
	29	36 N	2 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL WENT DRY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	P	-	HARDPAN	Surface	22
-	-	C	-	CLAY	22	57
-	-	G	U	MUDDY GRAVEL	57	59
-	H	G	-	HARD GRAVEL	59	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	280 ASTM A53B 18.97 # WELD JT WHEATLAND	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRAN. BENTONITE	Surface		

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 52 ft. below surface
Pumping at 4.5 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RK		03-21-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52	Septic or Holding, or POWTS Tank		44

Comment:

Created On: 04-17-2018 Updated On: 04-17-2018 Review Status: