Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY082

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: HON, LORNA	Phone #: (715)321-2808
Mailing Address: 1583 BIEMERET ST	
City: GREEN BAY	State: WI — Zip Code: 54304
County: Rusk	Co. Permit #:
Notification #: 7104609801	Completed: 03-15-2018
Well Constructor (Business Name): RONALD A KOMAREK SR	Lic. #: 610
Facility ID # (Public Wells):	
Address: KOMAREK WELL DRILLING, OGEMA WI 54459	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Town of LAWRENCE	Fire # (if avail.): N2950
Street Address or Road Name and Number: HUNTERS LN	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.3947 °N -90.7808 °W	Method Code: GPS008
SW SW or Govt Lot #	Section: 29 — Township: 34 N — Range: 3 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	36

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	P	-	HARDPAN	Surface	14
-	-	G	-	GLACIAL COBBLES	14	21
-	-	S	-	SAND	21	23
-	-	C	-	CLAY	23	31
-	-	N	-	SANDSTONE	31	36

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	.280 ASTMA53B 18.97 # WELD JT WHEATLAND	Surface	31.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRAN. BENTONITE	Surface		

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 6 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJK		03-21-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Privy	>	50

Comment:

Created On: 04-17-2018 Updated On: 06-24-2020 Review Status: